

Latex Particle Challenge Final Report

Test Article: MCBJJ-1095-PFE
Study Number: 1196117-S01
Study Received Date: 25 Jun 2019
Testing Facility: Nelson Laboratories, LLC
6280 S. Redwood Rd.
Salt Lake City, UT 84123 U.S.A.
Test Procedure(s): Standard Test Protocol (STP) Number: STP0005 Rev 06
Deviation(s): None

Summary: This procedure was performed to evaluate the non-viable particle filtration efficiency (PFE) of the test article. Monodispersed polystyrene latex spheres (PSL) were nebulized, dried, and passed through the test article. The particles that passed through the test article were enumerated using a laser particle counter.

Three one-minute counts were performed, with the test article in the system, and the results averaged. Three one-minute control counts were performed, without a test article in the system, before and after each test article and the counts were averaged. Control counts were performed to determine the average number of particles delivered to the test article. The filtration efficiency was calculated using the average number of particles penetrating the test article compared to the average of the control values.

The procedure employed the basic particle filtration method described in ASTM F2299, with some exceptions; notably the procedure incorporated a non-neutralized challenge. In real use, particles carry a charge, thus this challenge represents a more natural state. The non-neutralized aerosol is also specified in the FDA guidance document on surgical face masks. All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Inside
Area Tested: 91.5 cm²
Particle Size: 0.1 µm
Laboratory Conditions: 21°C, 32% relative humidity (RH) at 0906; 20°C, 32% RH at 1018
Average Filtration Efficiency: 99.73%
Standard Deviation: 0.026

(THAILAND)
CO., LTD.



Curtis Leroy
Study Director

For
Janelle R. Bentz, M.S.

05 Jul 2019
Study Completion Date



1196117-S01

Results:

Test Article Number	Average Test Article Counts	Average Control Counts	Filtration Efficiency (%)
1	28	11,534	99.76
2	35	11,302	99.69
3	29	11,018	99.74
4	28	11,144	99.75
5	31	11,135	99.72



Bacterial Filtration Efficiency (BFE) and Differential Pressure (Delta P) Final Report

Test Article: MCBJJ-1095-BFE
Study Number: 1196118-S01
Study Received Date: 25 Jun 2019
Testing Facility: Nelson Laboratories, LLC
6280 S. Redwood Rd.
Salt Lake City, UT 84123 U.S.A.
Test Procedure(s): Standard Test Protocol (STP) Number: STP0004 Rev 16
Deviation(s): None

Summary: The BFE test is performed to determine the filtration efficiency of test articles by comparing the bacterial control counts upstream of the test article to the bacterial counts downstream. A suspension of *Staphylococcus aureus* was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at $1.7 - 2.7 \times 10^3$ colony forming units (CFU) with a mean particle size (MPS) of $3.0 \pm 0.3 \mu\text{m}$. The aerosols were drawn through a six-stage, viable particle, Andersen sampler for collection. This test method complies with ASTM F2101-14, Annex B, and AS4381:2015.

The Delta P test is performed to determine the breathability of test articles by measuring the differential air pressure on either side of the test article using a manometer, at a constant flow rate. The Delta P test was designed to comply with MIL-M-36954C, Section 4.4.1.2, and complies with AS4381:2015.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Inside
BFE Test Area: $\sim 40 \text{ cm}^2$
BFE Flow Rate: 28.3 Liters per minute (L/min)
Delta P Flow Rate: 8 L/min
Conditioning Parameters: $85 \pm 5\%$ relative humidity (RH) and $21 \pm 5^\circ\text{C}$ for a minimum of 4 hours
Test Article Dimensions: $\sim 177 \text{ mm} \times \sim 164 \text{ mm}$
Positive Control Average: 1.8×10^3 CFU
Negative Monitor Count: < 1 CFU
MPS: $2.9 \mu\text{m}$

(THAILAND)
CO., LTD.




Study Director

For
Janelle R. Bentz, M.S.

15 Jul 2019
Study Completion Date



1196118-S01

Results:

Test Article Number	Percent BFE (%)	Delta P (mm H ₂ O/cm ²)	Delta P (Pa/cm ²)
1	>99.9	2.2	21.7
2	99.5	2.5	24.2
3	99.6	2.5	24.5
4	99.4	2.3	22.9
5	99.8	2.2	21.1


The filtration efficiency percentages were calculated using the following equation:

$$\% BFE = \frac{C - T}{C} \times 100$$

C = Positive control average

T = Plate count total recovered downstream of the test article

Note: The plate count total is available upon request



Flammability of Clothing Textiles Final Report

Test Article: MCBJJ-1095-FTS
 Study Number: 1196119-S01
 Study Received Date: 25 Jun 2019
 Testing Facility: Nelson Laboratories, LLC
 6280 S. Redwood Rd.
 Salt Lake City, UT 84123 U.S.A.
 Test Procedure(s): Standard Test Protocol (STP) Number: STP0073 Rev 06
 Deviation(s): None

Summary: This procedure was performed to evaluate the flammability of plain surface clothing textiles by measuring the ease of ignition and the speed of flame spread. The parameter of time is used to separate materials into different classes, thereby assisting in a judgment of fabric suitability for clothing and protective clothing material. The test procedure was performed in accordance with the test method outlined in 16 CFR Part 1610 (a) *Step 1 - testing in the original state. Step 2 - Refurbishing and testing after refurbishing*, was not performed. All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Article Side Tested: Outside Surface
 Orientation: Machine

Test Criteria for Specimen Classification (See 16 CFR Part 1610.7):


Class	Plain Surface Textile Fabric
1	Burn time \geq 3.5 seconds
2	Not applicable to plain surface textile fabrics
3	Burn time $<$ 3.5 seconds


The 16 CFR Part 1610 standard specifies that 10 replicates are to be tested if, during preliminary testing, only 1 test article exhibits flame spread and it is less than 3.5 seconds or the test articles exhibit an average flame spread less than 3.5 seconds. Five replicates are to be tested if no flame spread is observed upon preliminary testing, if only 1 test article exhibits flame spread and it is equal to or greater than 3.5 seconds, or if the average flame spread is equal to or greater than 3.5 seconds. In accordance with the standard, 5 replicates were tested for this study.


Results:

Replicate Number	Time of Flame Spread
1	IBE
2	IBE
3	IBE
4	IBE
5	IBE

IBE = Test Article ignited, but extinguished

 Study Director

 For
 Janelle R. Bentz, M.S.


 Study Completion Date



1196119-S01

Differential Pressure (Delta P) Final Report

Test Article: MCBJJ-1095-DPT
 Study Number: 1196120-S01
 Study Received Date: 25 Jun 2019
 Testing Facility: Nelson Laboratories, LLC
 6280 S. Redwood Rd.
 Salt Lake City, UT 84123 U.S.A.
 Test Procedure(s): Standard Test Protocol (STP) Number: STP0004 Rev 16
 Deviation(s): None

Summary: The Delta P test is performed to determine the breathability of test articles by measuring the differential air pressure on either side of the test article using a manometer, at a constant flow rate. The Delta P test was designed to comply with EN 14683:2019, Annex C.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Inside
 Delta P Flow Rate: 8 Liters per minute (L/min)
 Conditioning Parameters: 85 ± 5% relative humidity (RH) and 21 ± 5°C for a minimum of 4 hours
 Test Article Dimensions: ~179 mm x ~166 mm

Results:

Test Article Number	Delta P (mm H ₂ O/cm ²)	Delta P (Pa/cm ²)
1	3.7	35.9
2	4.1	40.0
3	4.1	40.5
4	4.1	40.3
5	4.2	41.2

(THAILAND)
CO., LTD.



Curtis Lerow
Study Director

Fo
Janelle R. Bentz, M.S.

05 Jul 2019
Study Completion Date



1196120-S01



Test Report

Date : 2020-10-30
No. : HC20100291

Page 1 of 2

Applicant(Code:01325844) : Med-Con (Thailand) Company Limited
20 Soi Ruammit, Rama 6 Road, Phayathai, Phayathai, Bangkok,
Thailand 10400

Description of Sample(s) : One submitted sample said to be 3 Ply Disposable Medical Facemask.
Country of Origin : Thailand

Sample(s) Received Condition(s): In plastic bag under
ambient temperature

Date Sample(s) Received : 2020-10-12

Date Tested : 2020-10-16 to 2020-10-28

Investigation Requested : Bacterial Filtration Efficiency 細菌過濾效率 (BFE) %
– *Staphylococcus aureus* 金黃色葡萄球菌 (ATCC 6538)

Method(s) Used : ASTM F2100-2019 9.1 & ASTM F2101-2019

LAU Yuk Kuen, Joey
Authorized Signatory
Chemical and Food Department
For and on behalf of
The Hong Kong Standards and Testing Centre Ltd



In the event of any discrepancy between the English and Chinese versions of the text mentioned before, the English version shall prevail to the extent of such discrepancy only.

The Hong Kong Standards and Testing Centre Limited 香港標準及檢定中心有限公司
10 Dai Wang Street, Tai Po Industrial Estate, Tai Po, N.T., Hong Kong 香港新界大埔工業邨大宏街10號
Tel: +852 2666 1888 Fax: +852 2664 4353 Email: hkstc@stc.group Website: www.stc.group

This report shall not be reproduced unless with prior written approval from The Hong Kong Standards and Testing Centre Limited.

For Conditions of Issuance of this test report, please refer to the overleaf and Website.

除非事先得到香港標準及檢定中心有限公司的書面批准，否則不得自行複印此報告。測試報告相關的簽發條款，請參閱背頁和本公司網頁。



Test Report

Date : 2020-10-30
No. : HC20100291

Page 2 of 2

Test Result(s):

Bacterial Filtration Efficiency 細菌過濾效率 (BFE) %
– *Staphylococcus aureus* 金黃色葡萄球菌 (ATCC 6538)

Specimen(s)	3 Ply Disposable Medical Facemask
1	>99.9%
2	>99.9%
3	>99.9%
4	>99.9%
5	>99.9%

Notes : - Control average 對照組的平均菌落數 : 1730 CFU
- Mean particle size 平均粒徑 : 3.1µm
- Testing side 測試面 : Outside of specimen 外側
- Testing area 測試面積 : 47 cm²

***** End of Test Report *****

簽發測試報告的條款

Conditions of Issuance of Test Reports

1. 香港標準及檢定中心有限公司（以下簡稱）『本公司』為提供符合下述條款的測試和報告，而接受有關樣品和貨品。本公司基於下述條款提供服務，下述條款為本公司與申請服務的個人、企業或公司（以下簡稱『客戶』）的協議。
All samples and goods are accepted by The Hong Kong Standards & Testing Centre Limited (the "Company") solely for testing and reporting in accordance with the following terms and conditions. The Company provides its services on the basis that such terms and conditions constitute express agreement between the Company and any person, firm or company requesting its services (the "Clients").
2. 由此測試申請所發出的任何報告（以下簡稱『報告』），本公司會嚴格地為客戶保密。未經本公司書面同意，報告的整體或部分不得複製，也不得用於廣告或非授權的其他用途。然而，客戶可以將本公司印製的報告或認可的副本，向其客戶、供貨商或直接相關的其他人出事或提交。除第3條款規定外，除非相關政府部門、法律或法院要求，否則未經客戶同意，本公司不得就本報告內容向任何第三方討論或披露。
Any report issued by the Company as a result of this application for testing service (the "Report") shall be issued in confidence to the Clients and the Report will be strictly treated as such by the Company. It may not be reproduced either in its entirety or in part and it may not be used for advertising or other unauthorized purposes without the written consent of the Company. The Clients to whom the Report is issued may, however, show or send it, or a certified copy thereof prepared by the Company to his customer, supplier or other persons directly concerned. Subject to clause 3, the Company will not, without the consent of the Clients, enter into any discussion or correspondence with any third party concerning the contents of the Report, unless required by the relevant governmental authorities, laws or court orders.
3. 本公司將有權透露有關測試的文件及/或檔案予任何第三方認證/認可機構作審核或其他相關用途。本公司無須因透露文件及/或檔案的內容負上任何責任。
The Company shall be at liberty to disclose the testing-related documents and/or files anytime to any third-party accreditation and/or recognition bodies for audit or other related purposes. No liabilities whatsoever shall attach to the Company's act of disclosure.
4. 除非相關政府部門、法律或法院要求，否則未經本公司預先書面同意，本公司無需，也並無義務到法院對有關報告作證。
The Company shall not be called or be liable to be called to give evidence or testimony on the Report in a court of law without its prior written consent, unless required by the relevant governmental authorities, laws or court orders.
5. 除非由本公司進行抽樣，並已在報告中說明，否則報告內的結果只適用於送測的樣品，不適用於批量。樣品相關信息由客戶提供，本公司不對樣品信息的真實性負責。
The results in Report apply only to the sample as received and do not apply to the bulk, unless the sampling has been carried out by the Company and is stated as such in the Report. The Clients provide the sample's relevant information, and the Company will not be liable for or accept responsibility for the truth of the sample information.
6. 當報告內有作出與規範或標準符合性聲明時，將採用ILAC-G8指導文件（及/或在電工類測試領域時的IEC Guide 115）[不確定度的置信率為95%]作為判定規則。
When a statement of conformity to a specification or standard is provided, the ILAC-G8 Guidance document (and/or IEC Guide 115 in the electrotechnical sector) with 95% coverage probability for the expanded uncertainty will be adopted as a decision rule for the determination of conformity.
7. 如本公司確定報告被不當地使用，本公司保留撤回報告的權利，並有權要求其它適當的額外賠償。
In the event of the improper use of the report as determined by the Company, the Company reserves the right to withdraw it, and to adopt any other additional remedies which may be appropriate.
8. 本公司接受樣板進行測試的前提是，該測試報告不能作為針對本公司法律行動的依據。
Sample submitted for testing are accepted on the understanding that the Report issued cannot form the basis of, or be the instrument for, any legal action against the Company.
9. 如因使用本公司任何報告內的資料，或任何傳播信息所描述與之有關的測試或研究導致的任何損失或損害，本公司概不負責。
The Company will not be liable for or accept responsibility for any loss or damage howsoever arising from the use of information contained in any of its Reports or in any communication whatsoever about its said tests or investigations.
10. 若需要在法院審理程序或者仲裁過程中使用測試報告，客戶必須在提交測試樣品前將該意圖告知本公司。
Clients wishing to use the Report in court proceedings or arbitration shall inform the Company to that effect prior to submitting the sample for testing.
11. 該測試報告的支持數據和信息本公司只保存4年。個別評審機構有特別要求的，檢測數據和報告的保存期限可依情況變動。一旦超過上述提及的保存期限，數據和信息將被處理掉。任何情況下，本公司不必提供任何被處理的過期數據或信息。即使本公司事先被告知可能會發生相關損害，本公司在任何情況下也不必承擔任何損害，包括（但不限於）補償性賠償、利潤損失、數據損失、或任何形式的特殊損害、附帶損害、間接損害、從屬損害或任何違反約定、違反承諾、侵權（包括疏忽）、產品責任或其他原因產生的懲罰性損害。
Subject to the variable length of retention time for test data and report stored hereinto as to otherwise specifically required by individual accreditation authorities, the Company will only keep the supporting test data and information of this test report for a period of four years. The data and information will be disposed of after the aforementioned retention period has elapsed. Under no circumstances shall we provide any data and information which has been disposed of after the retention period. Under no circumstances shall we be liable for damages of any kind, including (but not limited to) compensatory damages, lost profits, lost data, or any form of special, incidental, indirect, consequential or punitive damages of any kind, whether based on breach of contract of warranty, tort (including negligence), product liability or otherwise, even if we are informed in advance of the possibility of such damages.
12. 報告的簽發記錄可通過登錄網站www.stc.group查詢。如需進一步查詢報告的有效性或核實報告，需與本公司聯繫。
Issuance records of the Report are available on the internet at www.stc.group. Further enquiry of validity or verification of the Reports should be addressed to the Company.